



Commercial Building - Fire Separation Inspection

Request this inspection when fire-stopping is complete but not covered up. This inspection is conducted **by request only**.

Prepare

Learn about [how to prepare for your inspection](#).

Check

The following are the most common items audited during this inspection. This list is not exhaustive. Compliance with the applicable codes and standards is required.

- The following are available on-site:
 - Fire-stopping catalogue details
 - Installer's fire-stopping certification
 - fire-stopping installation date
- Hallway/corridor/party wall separations are in place behind bulkheads or dropped ceilings
- Shafts are drywalled and taped with the appropriate layers of fire-rated gypsum board
- Fire extinguisher cabinets are drywalled and taped
- Fire dampers are installed

To request and if you have questions about scheduling a fire separation inspection please email buildingic@edmonton.ca.