

## MECH Hydronics Inspection

This inspection is necessary for commercial hydronic installations when the hydronic piping is installed and still exposed for inspection.

### **Prepare**

Learn about [how to prepare for your inspection](#).

### **Check**

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Hydronic loops and maximum lengths are installed and comply with CSA B214.
- Manifolds and tubing air test assembly is installed and holding pressure (accessible without a ladder or lift)