

Plumbing Stacks Inspection

This inspection is necessary when new or renovated piping for drainage and water supply is installed above grade.

Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- All piping is exposed for visual inspection; no drywall, insulation, vapour barrier or spray foam has been installed
- In-wall and above-ceiling piping has been installed and meets the National Plumbing Code (NPC) standards:
- Pipes have proper grade and adequate support
- Water supply lines are properly sized.
- Rough-in valves are to be installed and CSA approved.
- Waterlines and drainage piping to be protected from freezing.
- Appropriate piping materials to be installed for that application.